



Mob. : 9810725241
9213534855

R.S. YADAV & ASSOCIATES

Regd. Structural Engineers, Architects
& Govt. Approved Valuers for Income Tax,
Wealth Tax, Bank, Loan & Structure Audit Report
and Rain Water Harvesting Work etc.
E-mail : rsyadavengineer@gmail.com

Ref.: RSYA/2025/020

Dated : 28/05/2025

STRUCTURE STABILITY CERTIFICATE

Certified that I have personally inspected the School building known as "**BHARAT PUBLIC SCHOOL**" in Property No.A-J-1/10, in Khasra No.43, Saurabh Vihar, Hari Nagar Extension, Jaitpur Road, Badarpur, New Delhi-110044. The building is designed on the basis of calculations and satisfies the safety requirements. As per visual inspection of the building, it is further certified that the structure of the building is safe and sound for School purpose.

Note: This Certificate is valid for One Year from the Date of Issuance.



Er. R.S. YADAV
Regd. Civil Engineer
Structure Engineer &
Member of Institute of Valuer
Office : Chamber No. 61, Typist Block,
Civil Side, Tis Hazari Courts, Delhi - 110054



Associates:- **S.C. GUPTA**
Govt. Regd., Approved Valuer
CAT-I/678/193. 2017-18

SANTOSH YADAV
Diploma in Civil Engineering



MUNICIPAL CORPORATION OF DELHI
9th Floor, Dr. S. P. M. Civic Centre,
Minto Road , New Delhi - 110002
Structural Engineer Renewal Certificate

License No: sa/0179

Dated: 2025-02-27

Shri / Smt. / Ms **RAMASHRAY YADAV** S/o, W/o, D/o Sh. **KAILASH NATH YADAV** R/o **B-1233 GALI NO 35 SANT NAGAR BURARI DELHI DELHI 110084** has been registered as a Structural Engineer. He / She has deposited the applicable fee as per policy of the Department on account of **issuance** of License for Structural Engineer through **1** mode. This License will be valid up to **31/Dec/2025** in Municipal Corporations of Delhi for the above-named Structural Engineer with the following competency:-

Structural Engineer:

1. To prepare the structure design, calculations and details for all buildings and supervision thereof.
2. In case of structural failure, the sole responsibility lies on the part of Structural Engineer and action can be initiated as per Law.

Penal Action:

1. Penal action against defaulting Structural Engineer can be taken as per the provision of Unified Building Bye Laws of Delhi-2016.
2. The above Professional shall ensure compliance of relevant provisions of Building Bye Laws to be read with relevant Regulations applicable for the Licensing of Structural Engineer framed by three Municipal Corporations of Delhi from time to time as well as Undertaking submitted by him at the time of
3. The license is valid only for the purpose of building permits & supervision of construction, regularization cases and completion certificate cases only under the jurisdiction of Municipal Corporation of Delhi.



Signature valid

Digitally signed by Rahul Verma
Date: 2025.02.27 13:12:45 IST

Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi

Disclaimer: This certificate has been issued online by the system based on details and documents submitted by the applicant. The veracity of the certificate & document submitted by the applicant is the sole responsibility of the applicant & in case of any misrepresentation the applicant will be severally liable for the same.



BHARAT PUBLIC SCHOOL

[CBSE AFFILIATED & RECOGNISED]

J-1/10, Saurabh Vihar (Jaitpur), New Delhi - 110 044

Tel. : 09773764963

email ID : bps@bharatpublicschool.co.in

Website : bharatpublicschool.co.in

ID No. : 1925361

CBSE SCHOOL CODE : 25420

CBSE AFFILIATION NO. : 27308

Ref. No. ...BPS/2025/110024

To

The Health Officer,
South Delhi Municipal Corporation,
Central Zone, Lajpat Nagar,
New Delhi-110024



Date: 28/11/2025

Sub.: Request to issue fresh School Certificate (Health) to Bharat Public School, J-1/10, Saurabh Vihar, Near Shiv Mandir, Badarpur, New Delhi.

Sir,

This is in reference to the above mentioned subject, I am to say that the school require fresh School Certificate (Health) for which I am enclosing the following documents:-

1. Health Certificate dated 08/11/2019
2. Fire Certificate dated 02/01/2019 valid up to 02/01/2022
3. Copy of Rent Deed/Lease Deed/Perpetual Lease Deed
4. Building Details (Total Rooms - 53)
5. Class-wise enrolment of students (625 Boys & 352 Girls)
6. Staff strength
Male= 13 Female= 40
7. Building Plan/Map
8. Details of Toilets and water taps
Boys = 24 Urinals + 16 WCs Girls = 24 WCs Staff= 04 WCs
9. Electricity bill

Therefore, you are requested to issue School Certificate (Health) to the school at the earliest and oblige.

Thanking you,



RRTQ LABS PRIVATE LIMITED

(Reliable Results With True Quality)

A Government Registered and ISO 9001:2015 Certified Laboratory

Address: Plot No. 117A/3, Khasra No. 180, Near Cosmos School,
Tajpur Road, Molarband Extn, Badarpur, New Delhi - 110044

E-mail : rrtqlabs@gmail.com | website : www.rrtqlabs.com | Ph: 7827322303, 9355616901, 9355616902

TEST REPORT

Name & Address of Customer		Test Report Number	W20250524001
Issued to, M/s. BHARAT PUBLIC SCHOOL, J-1/10, Saurabh Vihar, Jaitpur, New Delhi - 110044		ULR No.	TC154242500000071F
		Date of Report	28.05.2025
		Job Number	RL/23052501
		Sample Description	One Sample of Drinking Water
		Date of Sampling	24.05.2025
		Sampling Done by	Mr. Saurabh (Lab Representative)
		Type of Sampling	Grab
Sample Name	Drinking Water	Sampling Protocol	IS 17614 (Part 1): 2021
Sample Received on	24.05.2025	Sample Quantity	1 Litre
Analysis Started on	24.05.2025	Sample Packing	Plastic Bottle
Analysis Completed on	28.05.2025	Sample Marking	Drinking Water (RO Water)

RESULTS

S.No.	Parameters	Unit	Results	Requirement as per IS: 10500-2012		Test Method
				Acceptable Limit	Permissible Limit in the absence of alternate source	
1.	Colour	CU	< 5.0	5 Max	15 Max	IS 3025 (Part 4): 2021
2.	pH Value	--	7.11	6.5 to 8.5	No relaxation	IS 3025 (Part 11): 2022
3.	Turbidity	NTU	< 1.0	1 Max	5 Max	IS 3025 (Part 10): 2023
4.	Total Dissolved solids	mg/l	70.2	500 Max	2000 Max	IS 3025 (Part 16): 2023
5.	Total Hardness (as CaCO ₃)	mg/l	39.8	200 Max	600 Max	IS 3025 (Part 21): 2009
6.	Calcium (as Ca)	mg/l	8.0	75 Max	200 Max	IS 3025 (Part 40): 2024
7.	Magnesium (as Mg)	mg/l	4.8	30 Max	100 Max	IS 3025 (Part 46): 2023
8.	Chloride (as Cl)	mg/l	37.7	250 Max	1000 Max	IS 3025 (Part 32): 1988
9.	Sulphate (as SO ₄)	mg/l	12.5	200 Max	400 Max	IS:3025 (Part 24/sec1): 2022
10.	Fluoride (as F)	mg/l	0.3	1 Max	1.5 Max	IS:3025 (Part 60/Sec1): 2008
11.	Iron (as Fe)	mg/l	< 0.05	1.0 Max	No relaxation	IS:3025 (Part 53): 2024
12.	Total Alkalinity (as CaCO ₃)	mg/l	45.1	200 Max	600 Max	IS 3025 (Part 23): 2023
13.	Nitrate (as NO ₃)	mg/l	< 1.0	45 Max	No relaxation	IS 3025 (Part 34/sec1): 2023

Remarks: The above tested parameters meet the requirements as per IS: 10500-2012. Hence sample is potable based on the tests carried out.

End of Report



TC-15424

Page 01 of 01

For RRTQ LABS PRIVATE LIMITED

R. Roshan
Rajesh Kumar Roshan
(Managing Director)

AUTHORISED SIGNATORY

Neeraj
CHECKED BY

Format No.: RL/QF/7.8/01

- Note :**
- The results are related to the test items only.
 - Sample will be destroyed after two weeks from the date of issue of test report.
 - This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertisement media without written consent.
 - Laboratory is not responsible for customer provided details.
 - When report is without NABL symbol & URL, it implies that these products & tests are not covered under NABL accredited scope.



RRTQ LABS PRIVATE LIMITED

(Reliable Results With True Quality)

A Government Registered and ISO 9001:2015 Certified Laboratory

Address: Plot No. 117A/3, Khasra No. 180, Near Cosmos School,
Tajpur Road, Molarband Extn, Badarpur, New Delhi - 110044

E-mail : rrtqlabs@gmail.com | website : www.rrtqlabs.com | Ph: 7827322303, 9355616901, 9355616902

TEST REPORT

Name & Address of Customer		Test Report Number	W20250524001A
Issued to, M/s. BHARAT PUBLIC SCHOOL, J-1/10, Saurabh Vihar, Jaitpur, New Delhi - 110044		Date of Report	28.05.2025
		Job Number	RL/24052501A
		Sample Description	One Sample of Drinking Water
		Date of Sampling	24.05.2025
		Sampling Done by	Mr. Saurabh (Lab Representative)
		Type of Sampling	Grab
Sample Name	Drinking Water	Sampling Protocol	IS 17614 (Part 1): 2021
Sample Received on	24.05.2025	Sample Quantity	1 Litre
Analysis Started on	24.05.2025	Sample Packing	Plastic Bottle
Analysis Completed on	28.05.2025	Sample Marking	Drinking Water (RO Water)

RESULTS

S.No.	Parameters	Unit	Results	Requirement as per IS: 10500-2012		Test Method
				Acceptable Limit	Permissible Limit in the absence of alternate source	
1.	Odour	--	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
2.	Taste	--	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3.	Total Coliform	MPN/100ml	Absent	Shall not be detectable in any 100 ml sample		IS 15185: 2016
4.	Escherichia coli	MPN/100ml	Absent	Shall not be detectable in any 100 ml sample		IS 15185: 2016

Remarks: The above tested parameters meet the requirements as per IS: 10500-2012. Hence sample is potable based on the tests carried out.

End of Report

Page 01 of 01

Reera
CHECKED BY

Format No.: RL/QF/7.8/01

For RRTQ LABS PRIVATE LIMITED

R. Roshan
Rajesh Kumar Roshan
(Managing Director)

AUTHORISED SIGNATORY

Note :

- The results are related to the test items only.
- Sample will be destroyed after two weeks from the date of issue of test report.
- This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertisement media without written consent.
- Laboratory is not responsible for customer provided details.
- When report is without NABL symbol & URL, it implies that these products & tests are not covered under NABL accredited scope.